

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2010037
Permit #: 01461-2023CAT
Request Rec'd: 12/12/2023
Approval Date:12/13/2023 DS
Permit Expires: 06/13/2024

<u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

12100 Palos Heights, LLC 1983 Rt. 52, Suite 1 A Hopewell Junction, NY 12533

(None) County

Contact: Patty Garcia 845/765-8507

FACILITY

- name and address where tanks are located:

Palos Heights, LLC 12100 S. Ridgeland Palos Heights, IL 60463

Cook County

Contact: Sameer Alaiwi 845/765-8507

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	12,000	Currently in use	Federal
5	Gasoline - Premium	12,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection -	Sacrificial Anode Cathodic	Replacing - Corrosion Prot - Piping - Fiberglass Non-
Piping	Protection	Corrosive

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection -	Sacrificial Anode Cathodic	Replacing - Corrosion Prot - Piping - Fiberglass Non-
Piping	Protection	Corrosive

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Install new anodes in (2) STP sumps.

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company	Contact Person: Warren Cherner Phone: 847/465-4000			
1111 West Dundee Road Wheeling, IL 600903936	Email: warren@metrotank.com Contractor License # IL102 Exp. 9/20/2025			

Sincerely, Daniel J. Starks

Daniel Starks