

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2014573
Permit #: 01468-2023UPG
Request Rec'd: 12/14/2023
Approval Date:12/14/2023 DS
Permit Expires: 06/14/2024

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County

Contact: Zachary M. Davis 937/203-7827

**FACILITY** 

- name and address where tanks are located:

Speedway #7540 948 North Farnsworth Ave. Aurora, IL 60605 Kane County

Contact: Store Manager 937/863-6513

#### Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Mid-grade	10,000	Currently in use	Federal

#### **Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

#### **Summary of Work**

The flex is leaking in mid grade so repalcing felx connector

#### **Special Contingencies**

NOTE: A sump must be installed if not already present

### PERSON, FIRM OR COMPANY PERFORMING WORK:

aniel y. Starke

America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9

Aurora, IL 60504

Contact Person: Ravindra Penmatsa

Phone: 312/286-6722 Email: ravi@ampsco.net

Contractor License # IL002420 Exp. 5/22/2025

Sincerely,

Daniel Starks