

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety 1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov

SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

 Facility #:
 2045958

 Permit #:
 01469-2023UPG

 Request Rec'd:
 11/09/2023

 Approval Date:12/14/2023 DS

 Permit Expires:
 06/14/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	FACILITY - name and address where tanks are located:
County of McHenry 2200 N. Seminary Ave. Woodstock, IL 60098 McHenry County	County of McHenry - Jail 2200 N. Seminary Avenue Woodstock, IL 60098 McHenry County
Contact: Brian Krause 815/334-4819	Contact: Richard Rose 815/334-0105

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	6,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
🛏 Leak Detection - Pinina	Sump Sensor in Single Wall STP/Tanktop Sump	Removing

Summary of Work

The USt system s for back up generator. Piping is non regulated European suction. We are removing the sump sensor. The containment sump will remain in place but we are deregulating the containment sump.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:		
Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: bob@crownetank.com Contractor License # IL002345 Exp. 5/16/2024	

Sincerely,

Janiel J. Starke

Daniel Starks