



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2006916
Permit #: 01470-2023UPG
Request Rec'd: 12/14/2023
Approval Date: 12/17/2023 DS
Permit Expires: 06/18/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: First Business Enterprise 273 East 147th Harvey, IL 60504 Coles County Contact: Mirza Baig 773/317-8099	FACILITY - name and address where tanks are located: Shell 273 East 147th Street Harvey, IL 60426 Cook County Contact: Mirza Baig 708/596-6006
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	12,000	Currently in use	Federal
5	Gasoline - Premium	8,000	Currently in use	Federal
6	Diesel Fuel	7,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron 4000 L single wall vent	New

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron 4000 L single wall vent	New

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron 4000 L single wall vent	New
Piping	Shear Valves	New

Summary of Work

The vent stack was hit by a car so repairing portion of vent lines and replace the shaer valve on DSL dispenser

Special Contingencies

NOTE: A dispenser sump must be installed where the shear valve is being replaced if one doesn't already exist

PERSON, FIRM OR COMPANY PERFORMING WORK:

America Petropump Services LLC d/b/a Ampsco Services
4075 Fox Valley Center Dr., Unit 9
Aurora, IL 60504

Contact Person: Ravindra Penmatsa
Phone: 312/286-6722
Email: ravi@ampsco.net
Contractor License # IL002420 Exp. 5/22/2025

Sincerely,



Daniel Starks