



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2020304
Permit #: 01476-2023UPG
Request Rec'd: 12/15/2023
Approval Date: 12/18/2023
Permit Expires: 06/18/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Northern Associates, Inc. 2545 W. Peterson Ave., Suite 101 Chicago, IL 60659 Cook County Contact: Nusrat H. Choudhri 773/835-7786	FACILITY - name and address where tanks are located: Mobil Gas Station 251 West 63rd Street Chicago, IL 60621 Cook County Contact: Nusrat H Choudhri 773/483-1200
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	12,000	Currently in use	Federal
5	Gasoline - Mid-grade	12,000	Currently in use	Federal
6	Gasoline - Premium	12,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Summary of Work

Replacing wireless electronic leak detection with mechanical leak detection.


Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC
1058 National Parkway
Schaumburg, IL 601734519

Contact Person: Chris Derro
Phone: 708/717-2676
Email: cderro@cardinalcompliance.net
Contractor License # IL002418 Exp. 3/21/2025

Sincerely,

A handwritten signature in black ink that reads "Sean Keane". The signature is written in a cursive style with a horizontal line underneath the name.

Sean Keane