



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 2038218  
Permit #: 01477-2023CAT  
Request Rec'd: 12/18/2023  
Approval Date: 12/18/2023 DS  
Permit Expires: 06/18/2024

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|   |   |
|---|---|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Joe Boudakh<br>7820 N. Avers Ave.<br>Skokie, IL 60076<br>Cook County<br>Contact: Joe Boudakh 224/522-1571 | <b>FACILITY</b><br>- name and address where tanks are located:<br>South Park Marathon<br>525 W. Talcott<br>Park Ridge, IL 60068<br>Cook County<br>Contact: Danny Boudakh 224/628-0124 |
|---|---|

**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1      | Gasoline - Regular | 10,000   | Currently in use | Federal          |
| 2      | Gasoline - Premium | 10,000   | Currently in use | Federal          |
| 3      | Diesel Fuel        | 6,000    | Currently in use | Federal          |

**Tank 1 Equipment**

| Equipment Type                | Permit Equipment                      | Action  |
|-------------------------------|---------------------------------------|---|
| Corrosion Protection - Tank   | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection   |
| Corrosion Protection - Piping | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection |

**Tank 2 Equipment**

| Equipment Type                | Permit Equipment                      | Action  |
|-------------------------------|---------------------------------------|---|
| Corrosion Protection - Tank   | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection   |
| Corrosion Protection - Piping | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection |

**Tank 3 Equipment**

| Equipment Type                | Permit Equipment                      | Action  |
|-------------------------------|---------------------------------------|---|
| Corrosion Protection - Tank   | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection   |
| Corrosion Protection - Piping | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection |

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**


**Special Contingencies**

**Summary of Work**

The project would follow saw cuts to each anode location and confirm cabling to rectifier is good, and then replace anode(s) at each location. Anodes would be installed vertically to a depth of that puts anode below frost and in good soil. The site will surveyed after repair.

| PERSON, FIRM OR COMPANY PERFORMING WORK:  |   |
|---|---|
| Advanced Corrosion Control Technologies., Inc.<br>4664 North DuBay Drive<br>Mosinee, WI 54455 | Contact Person: Timothy Sievert<br>Phone: 262/960-3665<br>Email: timothysievert@gmail.com<br>Contractor License # IL2072 Exp. 3/22/2024 |

Sincerely,

  
\_\_\_\_\_

Daniel Starks