



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3025265
Permit #: 01485-2023UPG
Request Rec'd: 12/19/2023
Approval Date: 12/19/2023 DS
Permit Expires: 06/20/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Thorntons, LLC 2600 James Thornton Way Louisville, KY 40245 Jefferson County Contact: Maggie Seagh 502/425-8022	FACILITY - name and address where tanks are located: Thornton Oil #351 107 Spring Creek Rd. East Peoria, IL 61611 Tazewell County Contact: Tammy Schreiber 309/694-1777
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
11	Gasoline - Regular	20,000	Currently in use	Federal
12	Gasoline - Premium	10,000	Currently in use	Federal
13	E85	10,000	Currently in use	Federal
14	B-11	10,000	Currently in use	Federal
15	Kerosene	6,000	Currently in use	Federal
16	B-11	6,000	Currently in use	Federal

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor

Tank 13 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor

Tank 14 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor

Tank 15 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor

Tank 16 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor


Summary of Work

Replacing existing TLS 350 with new TLS450 plus with CSLD.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313	Contact Person: Carrie Baker Phone: 515/601-6635 Email: jfranklin@senecaco.com Contractor License # IL598 Exp. 2/23/2024

Sincerely,



Daniel Starks