



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	2021621
Permit #:	01449-2023UPG
Request Rec'd:	12/12/2023
Amended Date:	12/20/2023 DS
Approval Date:	12/12/2023 DS
Permit Expires:	06/12/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Thorntons, LLC 2600 James Thornton Way Louisville, KY 40245 Jefferson County Contact: Maggie Seagh 502/425-8022	FACILITY - name and address where tanks are located: Thornton #7 2640 Mannheim Rd Franklin Park, IL 60131 Cook County Contact: Tony 847/455-3066
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	12,000	Currently in use	Federal
6	Gasoline - Mid-grade	12,000	Currently in use	Federal
7	Gasoline - Premium	12,000	Currently in use	Federal
8	Kerosene	6,000	Currently in use	Federal
9	Diesel Fuel	6,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	North - Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	North - Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	North - Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	North - Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	North - Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus

Summary of Work

Remove existing VR & install new VR 450+ PLLDs

Special Contingencies

Amendment Reason:


Noticed tank 9 was entered as a 450Plus but should have ad CSLD included. tank 9 should be listed as a veeder root 450 plus with CSLD

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 815/398-6250
Email: amberp@stenstrom.com
Contractor License # IL1890 Exp. 4/12/2024

Sincerely,



Daniel Starks