



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Revised

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 2021621 |
| Permit #: | 01449-2023UPG |
| Request Rec'd: | 12/12/2023 |
| Approval Date: | 12/12/2023 DS |
| Extension Date: | 12/21/2023 |
| Permit Expires: | 06/12/2024 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Thorntons, LLC 2600 James Thornton Way Louisville, KY 40245 Jefferson County Contact: Maggie Seagh 502/425-8022 | FACILITY - name and address where tanks are located: Thornton #7 2640 Mannheim Rd Franklin Park, IL 60131 Cook County Contact: Tony 847/455-3066 |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|----------------------|----------|------------------|------------------|
| 5 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 6 | Gasoline - Mid-grade | 12,000 | Currently in use | Federal |
| 7 | Gasoline - Premium | 12,000 | Currently in use | Federal |
| 8 | Kerosene | 6,000 | Currently in use | Federal |
| 9 | Diesel Fuel | 6,000 | Currently in use | Federal |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|-----------------------------------------------------------|---------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|-----------------------------------------------------------|---------------------------------------------------------------------------------------|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|-----------------------------------------------------------|---------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Tank 8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|-----------------------------------------------------------|---------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Tank 9 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|-----------------------------------------------------------|----------------------------------------------------------------------------------|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus |

Summary of Work

Remove existing VR & install new VR 450+ PLLDs

Special Contingencies**Amendment Reason:**

Noticed tank 9 was entered as a 450Plus but should have ad CSLD included. tank 9 should be listed as a veeder root 450 plus with CSLD

Amendment Reason:


Noticed tank 9 was entered as a 450Plus but should have ad CSLD included. tank 9 should be listed as a veeder root 450 plus with CSLD

Revision Reason:

Fix the amended permit to include the original permitted tank & piping leak detection to display properly on final permitted version.

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------|
| Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108 | Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: amberp@stenstrom.com Contractor License # IL1890 Exp. 4/12/2024 |

Sincerely,



Daniel Starks