



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 4040687  
Permit #: 01494-2023CAT  
Request Rec'd: 12/21/2023  
Approval Date: 12/22/2023 DS  
Permit Expires: 06/24/2024

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Decatur Real Estate Investment, LLC 955 Malinda Court Forsyth, IL 62535 Macon County Contact: Lakhwinder S. Pelia 217/864-9887	<b>FACILITY</b> - name and address where tanks are located: Macon Petroleum, Inc. d/b/a P & V Quick Stop 399 E. Andrews Macon, IL 62544 Macon County Contact: Lakhwinder S. Pelia 217/864-9887
--	--

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	12,000	Currently in use	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector

**NACE Certified Designer**

**NACE Certified Designer Number**

**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Summary of Work**

Replacing failed cathodic protection sacrificial anode on STP flex with 2 5lb anodes

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Midwest Tank Testing Company 326 Eiler Drive Gifford, IL 61847	Contact Person: Stephen Hall Phone: 217/714-4305 Email: midwesttanktestingsth@aol.com Contractor License # IL752 Exp. 3/17/2025

Sincerely,

Daniel Starks