



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**

Facility #: 2026186  
Permit #: 01374-2023UPG  
Request Rec'd: 10/30/2023  
Amended Date: 12/26/2023 DS  
Approval Date: 11/29/2023 DS  
Permit Expires: 05/29/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Mahy Investments, LLC 12658 S. Wood Calumet Park, IL 60827 Cook County Contact: Yafai Hussain 708/385-9880	<b>FACILITY</b> - name and address where tanks are located: Mahy Investments, LLC - Citgo 12658 S. Wood Street Calumet Park, IL 60827 Cook County Contact: Yafai Hussain 708/385-9880
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	12,000	Currently in use	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Positive Shutoff Valves	New

**Summary of Work**

The tank 2 fueling system will be converted to sell E85 product. The Dispenser #7/8 and its hose & nozzle set, STP with flex connector, MLLD and ball valve, sump sensor, overfill prevention drop tube and probe will be changed to items compatible with E85 product.

11/29/23, The final inspection for the Kerosene spill container replacement violation was this morning.

**Special Contingencies**

**Amendment Reason:**


Tank #2 will be the tank converted to E85. A new compatibility form will be submitted. Listed conversion of tank 1. Tank 2 was converted

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

B & K Equipment Company  
2939 175th Street  
Lansing, IL 60438

Contact Person: Ed Angell  
Phone: 708/474-3344  
Email: ed@bkequip.com  
Contractor License # IL1207 Exp. 2/14/2024

Sincerely,



---

Daniel Starks