



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3038610
Permit #: 01506-2023UPG
Request Rec'd: 12/28/2023
Approval Date: 12/28/2023 DS
Permit Expires: 06/28/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Brandt Construction Company 700 4th Street West Milan, IL 61264 Rock Island County Contact: Terry Brandt 309/787-4644	FACILITY - name and address where tanks are located: Brandt Construction Company 102 7th Street West Milan, IL 61264 Rock Island County Contact: Anna Copeland 309/787-4644
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Dyed Diesel	10,000	Currently in use	Federal
2	Diesel Fuel	10,000	Currently in use	Federal
3	Gasoline - Regular	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	New

Summary of Work

Removing ball floats and Insalling overfill prevention drop tubes

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pipeco, Inc. 610 29th Street Bettendorf, IA 52722	Contact Person: Robert Schafer Phone: 563/529-8502 Email: rob@pipoecoinc.com Contractor License # IL2034 Exp. 9/28/2024

Sincerely,

Daniel G. Starks

Daniel Starks