

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

Permit for Emergency Repair Request on 12/28/2023

FOR OFFICE USE ONLY

Facility #: 4042115
Permit #: 01508-2023UPG
Request Rec'd: 12/28/2023
Approval Date:12/28/2023 DS
Permit Expires: 01/09/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR TEN WORKING DAYS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Meyer Oil Company 1505 W. Main Street Teutopolis, IL 62467 Effingham County

Contact: Michael Meyer 217/703-1591

FACILITY

- name and address where tanks are located:

Mach 1 Food Shop Route 49 @ I-70 Casey, IL 62420 Clark County

Contact: Amy Hock 217/932-9205

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	15,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	Replacing - Piping - Flexible Double Wall Environ Geo Flex

Summary of Work

Replacing shear valve on dispenser 7/8

Special Contingencies

NOTE: UDC must be installed under a separate upgrade permit if not already existing

PERSON, FIRM OR COMPANY PERFORMING WORK:

niel J. Starke

UPC Enterprises, LC d/b/a United Petroleum Service

128 Millwell Drive

Maryland Heights, MO 63043

Contact Person: Terry Smith

Phone: 314/797-0468

Email: cbayne@unitedpetro.com

Contractor License # IL002402 Exp. 2/10/2024

Sincerely,

Daniel Starks