



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2020659
Permit #: 00004-2024UPG
Request Rec'd: 01/02/2024
Approval Date: 01/02/2024 DS
Permit Expires: 07/02/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Elburn Real Estate, LLC 213 S. Main Street Elburn, IL 601199119 Kane County Contact: SyedF.Quadri 630/673-8469	FACILITY - name and address where tanks are located: Elburn Real Estate, LLC 213 S. Main Street Elburn, IL 60119 Kane County Contact: Syed Sameeth 630/365-5900
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	6,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Flex Connector Steel	New

Summary of Work

RUL N STP has leaking fitting. Repiping submersible to fix leak. Installing flex connector where none currently exists. Replacing existing ball valve.

Special Contingencies

NOTE: A sump must be installed if one doesn't already exist

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/520-5292 Email: trevorh@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

Daniel Starks