



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2001602
Permit #: 00008-2024UPG
Request Rec'd: 01/02/2024
Approval Date: 01/03/2024 DS
Permit Expires: 07/03/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083 Lake County Contact: John Graham 847/223-3710	FACILITY - name and address where tanks are located: Bensenville #198 101 W. Irving Park Rd. Bensenville, IL 60106 Du Page County Contact: Julio Martinez 630/594-4903
--	---


Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Diesel Fuel	12,000	Currently in use	Federal
7	Diesel Fuel	12,000	Currently in use	Federal
8	Racing Fuel	12,000	Currently in use	Federal


Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Other Non-vented check valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
 Leak Detection - Piping	Sump Sensor with positive shutdown	New
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
 Leak Detection - Piping	Sump Sensor with positive shutdown	New
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

Summary of Work

Replacing the existing SW spill buckets on tanks #6, 7 & 8 w/ new DW Franklin Defender spill buckets. Replacing the existing overfill valves with new. Replacing the existing SW STP sumps with new SWFRP STP sumps. Replacing the existing STP's w/ new 2 hp FE Petro STP's. Revising the existing SWFRP piping only as needed to facilitate the installation of the new STP Sumps. Install new SW Nupi Semi-Rigid vent piping to new vent rank as shown on plan. Install new VR 323 sensors at STP sumps.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 12/8/2024

Sincerely,



Daniel Starks