



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 4003577
Permit #: 00018-2024CAT
Request Rec'd: 01/05/2024
Approval Date: 01/06/2024 DS
Permit Expires: 07/08/2024

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sunrise Petroleum, Inc. 502 North McKinley Mansfield, IL 61854 Piatt County Contact: Dinesh Chawla 217/637-3008	FACILITY - name and address where tanks are located: Sunrise Petroleum, Inc. 502 North McKinley Mansfield, IL 61854 Piatt County Contact: Dinesh Chawla 217/489-9021
---	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	10,000	Currently in use	Federal
6	Gasoline - Mid-grade	10,000	Currently in use	Federal
7	Gasoline - Premium	10,000	Currently in use	Federal
8	Diesel Fuel	8,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work


Replacing Failed Sacrificial Anodes on ALL STP Flex Connectors with 4 5lb anodes

PERSON, FIRM OR COMPANY PERFORMING WORK:

Midwest Tank Testing, LLC
2008 Medical Center Dr
Monticello, IL 61856

Contact Person: Stephen T. Hall
Phone: 217/714-4305
Email: midwesttanktestingsth@aol.com
Contractor License # IL002461 Exp. 1/2/2026

Sincerely,



Daniel Starks