



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2021041
Permit #: 00030-2024UPG
Request Rec'd: 01/09/2024
Approval Date: 01/09/2024
Permit Expires: 07/09/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Standard Bank & Trust Co. Trust number 19482 3759 W. Chicago Avenue Chicago, IL 60651 (None) County Contact: Suhail Assaf 708/710-4898	FACILITY - name and address where tanks are located: Hamlin Citgo, Inc. 3759 W. Chicago Avenue Chicago, IL 60651 Cook County Contact: Suhail Assaf 708/710-4898
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Diesel Fuel	4,000	Currently in use	Federal

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Shear Valves	New
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

Summary of Work

Replacing all fueling components to E85 compatibility for the Diesel tank

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: ben.olthoff@bkequip.com
Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

A handwritten signature in black ink that reads "Sean Keane". The signature is written in a cursive style with a horizontal line underneath the name.

Sean Keane