

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2013823
Permit #: 00045-2024UPG
Request Rec'd: 01/12/2024
Approval Date:01/12/2024 DS
Permit Expires: 07/12/2024

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS
- Corporation, partnership, or other business entity:
Your Local Gas, Inc.,
14112 Pulaski Road
Crestwood, IL 60418
Cook County
Contact: Mazhar Bhatti 708/699-9237

FACILITY
- name and address where tanks are located:
Your Local Gas, Inc.
273 W. Main Street
Glenwood, IL 60425
Cook County
Contact: Mazhar Bhatti 708/699-9237

#### Tanks on the Permit

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 6      | Gasoline - Regular | 8,000    | Currently in use | Federal          |

#### **Tank 6 Equipment**

| <b>Equipment Type</b> | Permit Equipment                 | Action   |
|-----------------------|----------------------------------|--|
| Leak Detection -      | Mechanical Pressurized Line Leak | Replacing - Leak Detect - Piping - Electronic Pressurized Line |
| Piping                | Detection                        | Leak Detection   |

### **Summary of Work**

Installing new mechanical leak detector on West Regular tank.

## **Special Contingencies**

Vaniel J. Starke

| PERSON, FIRM OR COMPANY PERFORMING WORK:                          |   |  |  |  |
|---|---|--|--|--|
| B & K Equipment Company<br>2939 175th Street<br>Lansing, IL 60438 | Contact Person: Ed Angell<br>Phone: 708/474-3344<br>Email: dj.white@bkequip.com<br>Contractor License # IL1207 Exp. 2/14/2024 |  |  |  |

Sincerely,

Daniel Starks