



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 5024636
Permit #: 00048-2024UPG
Request Rec'd: 01/12/2024
Approval Date: 01/12/2024 DS
Permit Expires: 07/12/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	FACILITY - name and address where tanks are located: Casey's General Stores Inc 902 East Park Taylorville, IL 62568 Christian County Contact: Steth Wahl 515/965-6238
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Diesel Fuel	6,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

upgrading nolead and diesel spill buckets to double wall spill buckets franklin 705555112CI-GKT

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2024

Sincerely,

Daniel Starks