



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**

Facility #: 2014582  
Permit #: 01466-2023UPG  
Request Rec'd: 12/14/2023  
Amended Date: 01/12/2024 DS  
Approval Date: 12/14/2023 DS  
Permit Expires: 06/14/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Anabi Real Estate Development, LLC, Designated Series E6 1450 N. Benson Avenue, Suite A Upland, CA 91786 (None) County Contact: Denise Soto 909/394-4728	<b>FACILITY</b> - name and address where tanks are located: Midwest Convenience, Inc. 499 W. Boughton Bolingbrook, IL 60440 Will County Contact: Eric Schuermann 847/507-9345
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
10	Gasoline - Regular	20,000	Currently in use	Federal
12	B-11	4,000	Currently in use	Federal
13	E85	4,000	Currently in use	Federal

**Tank 10 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Other Submersible Pump	New
Piping	Flex Connector Steel	New
Piping	Ball Valves	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
☛ Leak Detection - Piping	Sump Sensor	Reusing Existing

**Tank 12 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Piping	Flex Connector Steel	New

**Tank 13 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

**Summary of Work**

Replace singlewall stp sump, stp, riser, flex connector and ball valve on Diesel and RUL tanks. Replace drop tube and spill container on the E85 tank.

**Special Contingencies****Amendment Reason:**


Additional work required due to a new NOV for the E85 tank

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Anderson Pump Service, Inc.  
19659 South 97th Avenue  
Mokena, IL 60448

Contact Person: Ron Anderson  
Phone: 708/243-9081  
Email: Steve@andersonpump.com  
Contractor License # IL002275 Exp. 5/21/2024

Sincerely,



Daniel Starks