



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 4008063 |
| Permit #: | 00053-2024UPG |
| Request Rec'd: | 01/09/2024 |
| Approval Date: | 01/16/2024 DS |
| Permit Expires: | 07/16/2024 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: S & R Real Estate Consulting, Inc. 1095 US 45 Neoga, IL 62447 Cumberland County Contact: Savinder Singh 847/630-4916 | FACILITY - name and address where tanks are located: Neoga Truck Stop 1095 N. Rt. 45 Neoga, IL 62447 Cumberland County Contact: Savinder Singh 217/500-7436 |
|--|--|

Tanks on the Permit For Piping Only

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 10,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|--------------------------|--------|
| Piping | Steel Single Wall Piping | New |

Summary of Work

Replcing 28 inches of single wall steel pipe from submersible pump to swing joint.

Special Contingencies

| | |
|--|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Pemco Service Company, Inc. 1040 East Second Street Gilman, IL 60938 | Contact Person: William "Butch" VonDrehle Phone: 217/822-8628 Email: cmoore52@frontier.com Contractor License # IL1224 Exp. 2/26/2024 |

Sincerely,

Daniel Starks