



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2034510
Permit #: 00056-2024UPG
Request Rec'd: 01/15/2024
Approval Date: 01/16/2024
Permit Expires: 07/16/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Chicago Transit Authority 567 W. Lake St Chicago, IL 60661 Cook County Contact: Shile Liang 312/681-2747	FACILITY - name and address where tanks are located: Chicago Transit Authority Bus Facility 1843 W. 74th Street Chicago, IL 60636 Cook County Contact: Broughton Ronald 312/918-4658
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Used Oil	600	Currently in use	Federal

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

- Furnish and install a double wall suction line from the tank to the spill fill manhole located outside the stp sump. Line will attach to tank inside the stp sump and penetrate the sump wall to the double wall spill bucket right outside the sump.
- Furnish and install a double wall opw spill fill manhole , cap and adapter

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
K Plus Mechanical 10220 BODE ST Unit A Plainfield, IL 605851632	Contact Person: Tim Smith Phone: 815/216-7715 Email: tsmith@kplus.com Contractor License # IL002455 Exp. 10/26/2024

Sincerely,

Sean Keane