



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 6021687
Permit #: 00061-2024CAT
Request Rec'd: 01/17/2024
Approval Date: 01/17/2024 DS
Permit Expires: 07/17/2024

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: UK Corporation 599 Water Street Cahokia, IL 62206 St. Clair County Contact: 317/627-4870	FACILITY - name and address where tanks are located: UK Corporation d/b/a Harsh Food 599 Water Street Cahokia, IL 62206 St. Clair County Contact: Bill Sandhu 317/627-4870
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal
3	Gasoline - Regular	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection
Corrosion Protection - Piping	STP - Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection
Corrosion Protection - Piping	STP - Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection
Corrosion Protection - Piping	STP - Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

CP wires were cut next to the building. we will splice back together and install a manhole over repair. Test will be completed after repair.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/797-0468 Email: cbayne@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2024

Sincerely,



Daniel Starks