



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2026047
Permit #: 00062-2024UPG
Request Rec'd: 01/17/2024
Approval Date: 01/17/2024 DS
Permit Expires: 07/17/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: United Parcel Service 6700 W. 73rd Street Bedford Park, IL 60638 Cook County Contact: Angel Vellejo 708/496-7990	FACILITY - name and address where tanks are located: United Parcel Service 2301 N. Rose Street Franklin Park, IL 60131 Cook County Contact: Robert Adlam 708/451-3317
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Gasoline - Regular	12,000	Currently in use	Federal

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

Dispensers on the Permit

Dispenser	Action
1 UNL	Sump / Sensors Changing

Dispenser 1 UNL Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Summary of Work

Removing existing dispenser pan
removing existing shear valve
Install new under dispenser containment single wall Bravo
Installing new shear valve
testing line
backfill and resurface

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 630/878-6354 Email: jasonre@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

Daniel G. Starks

Daniel Starks