



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 5-007148
Permit # 00454-2007FLX
Request Rec'd 04/06/2007
Amended Date
Approval Date 4/6/2007 JC
Permit Expires 10/6/2007

Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Tri-Star Marketing, Inc. 2211 W. Bradley, P.O. Box 9279, Champaign, IL 61826-9279 Contact: Kathy Delsignore (217) 367-8387 Ext. 133	(2) FACILITY - name and address where tanks are located: Mobil Mart #17 1901 W. Jefferson Springfield, Sangamon Co., IL Contact: Kathy Delsignore (217) 367-8386
---	---

(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons
- (b) Type of flex connector(s):* (TK # 1) - (Installing) Steel flex connector at dispenser sump # 7/8 (see contingencies)
- (c) Product stored in each tank:* (TK # 1) - Gasoline
- (d) Corrosion Protection being installed with flex connector(s):* (TK # 1) - Existing containment sump

- (4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

- (5) SPECIAL CONTINGENCIES:** According to the permit application, this flex connector is being replaced under dispenser "# 7/8" and is being served by tank i.d. "#1" (reg. unleaded tank); however, this office cannot completely confirm what the tank i.d. #'s really are because of conflicting permit site plans from the past. Some past permits show tanks 1,2,3,4 in different locations within the tank field itself with respect to the different grades of fuel. The relation of each tanks position in the tank field is in question with regards to where they are relative to each other. This in turn raises confusion as to the piping configuration as it comes from the submersibles to just before they reach the first islands. (reference site plans for permits 01308-1999UPG, 00733-2001UPG and 02042-2002UPG). See also permit #00485-2005FLX that also replaced a flex connector in dispenser sump "# 7/8" (again, presumably being served by tank i.d. "#1"). This work for this present permit #00454-2007FLX has been previously completed under emergency repair procedures.

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Seneca Oil and Equipment 458 N. Hwy. 48, PO Box 60 Oreana, IL 62554	Contact Person: Chuck Hoenig Phone: Contractor Registration # Exp.
---	---

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)