



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 6-024645
Permit # 00352-2007CAT
Request Rec'd 03/19/2007
Amended Date
Approval Date 3/21/2007 JC
Permit Expires 9/21/2007

**Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          New Shivkrupo, LLC          40 N. 6th Street          Mascoutah, IL 62258          Contact:</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Han-Dee Mart          40 North 6th Street          Mascoutah, St. Clair Co., IL          Contact: Prince Patel (618) 398-6745</p>
---	---

**(3) UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:**

- (a) *Number and size of tanks having cathodic protection installed, upgraded, or repaired:* (TK # 1, 2, 3) - 10,000 gallons
- (b) *Type of tanks:* (TK # 1, 2, 3) - Existing single wall STI P3
- (c) *Type of piping:* (TK # 1, 2, 3) - Existing steel flex connectors, (TK # 1, 2, 3) - Existing single wall fiberglass
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (e) *Type of leak detection being used:*  
*Tank:* (TK # 1, 2, 3) - Existing automatic tank gauging,  
*Piping:*
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:* (TK # 1, 2, 3) - Existing fiberglass
- (g) *NACE certified designer:* *Certification number:* 5001
- (h) *Method of integrity assessment of tank(s) being used:* n / a; these tanks are stip3 and are using automatic tank gauging

**(4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p align="right">Contact Person:          Phone:          Contractor Registration #    Exp.</p>
--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)