



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Amended

FOR OFFICE USE ONLY
Facility # 7-007983
Permit # 00933-2012UPG
Request Rec'd 09/04/2012
Amended Date 10/16/2012
Approval Date 9/10/2012 JC
Permit Expires 3/10/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145 Contact: Kenny Kucker (309) 827-4676	(2) FACILITY - name and address where tanks are located: Travel Centers of America 4510 Broadway, PO Box 943 Mount Vernon, Jefferson Co., IL Contact: Marvin Niedbalski (618) 244-4242
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 2, 3, 4) - 20,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 2, 3, 4) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX from the tanks all the way through to all transition sumps and all dispenser islands. Also, a new siphon bar will connect across tank #2 & #3. Furthermore, a new transition sump will be installed between tanks #2 and #3 (the supply line coming from tank #4 will connect with the line from tank #3 just outside the vicinity of the tank field), (TK # 2, 3, 4) - (Installing) Submersible Sumps containment FRP to replace the existing sumps, (TK # 2, 3, 4) - (Installing) Dispenser Sumps containment FRP to replace the existing sumps, (TK # 2, 3, 4) - (Installing) Transition Sumps FRP fiberglass (one just outside of the tank field, and one near the far end of the truck islands that will further connect with new piping supplying the auto islands).
- (d) Product to be stored in each tank:* (TK # 2, 3, 4) - Diesel Fuel
- (e) Type of leak detection being used:*
 - Tank:**
 - Piping:** (TK # 2, 3, 4) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at all affected dispenser sumps, submersible sumps, and transition sumps. (There are existing line leak detectors).
- (f) Corrosion Protection being used:*
 - Tank:**
 - Piping:** (TK # 2, 3, 4) - (Installing) Fiberglass Non-Corrosive
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Saint Louis, MO 63139	Contact Person: Greg Spiros Phone: (314) 644-6000 Contractor Registration # IL-1910 Exp.
----------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------

Sincerely,

James J. Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)