

Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous

Substances.

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
2001 Oil Company 5333 Birchwood Avenue Skokie, IL 60077	2001 Oil Company 8001 Golf Road Niles, Cook Co., IL
Contact: Jan (847) 675-0005	Contact: Terry Theoropolus (312) 965-8330

(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6) 12,000 gallons, (TK # 7) 2,000 gallons, (TK # 8) 8,000 gallons, (TK # 9) 6,000 gallons
- (b) Type of flex connector(s): (TK # 6, 7, 8, 9) Existing steel flex connectors,
 - (c) Product stored in each tank: (TK # 6, 7, 8, 9) Gasoline
 - (d) Corrosion Protection being installed with flex connector(s): (TK # 6, 7, 8, 9) (Installing) Sacrificial anodes cathodic protection at dispenser sump #1/3 only.
- (4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at <u>www.state.il.us/osfm</u> or by calling (217)785-1020.
- (5) <u>SPECIAL CONTINGENCIES</u>: Anodes will only be placed at dispenser #1/3 which is being served by tanks 6,7,8,9 (the dispenser # and associated tank #'s will have to be further verified by the field inspector and amended if necessary).

(6) PERSON, FIRM OR COMPANY PERFORMING WOR	<u>K</u> :
Tanknology-NDE	Contact Person: Milly Morales Phone:
Elgin, IL 60123	Contractor Registration # Exp.

Sincerely,

Janu J Coffey

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)