

Division File (Rev. - 1/98)

(1) **OWNER OF TANKS** - Corporation, partnership, or other

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

Amended

FOR OFFICE USE ONLY

Facility # 5-020728
Permit # 00753-2006UPG
Request Rec'd 05/19/2006
Amended Date 06/14/2006
Approval Date 5/24/2006 JC
Permit Expires 11/24/2006

(2) **FACILITY** - name and address where tanks are located:

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

business entity:		
Thorntons, Inc. P. O. Box 34230, 10101 Linn Station Road, Suite 200 Louisville, KY 40223	Thornton Oil Corporation #369 2910 Woodlawn Rd Lincoln, Logan Co., IL	
Contact: Patty Height (800) 928-8022	Contact: Burwell Eric (217) 735-4493	
3) <u>UPGRADE OR REPAIR OF TANKS:</u>		
(a) Number and size of tanks being upgraded or repaired	: (TK # 7) - 12,000 gallons	
(b) Type of tanks: (TK # 7) - Existing single wall fiberglas	SS	
(c) Type of piping: (TK # 7) - (Installing) Double wall fib	erglass	
(d) Product to be stored in each tank: (TK # 7) - Soy Oil		
(e) Type of leak detection being used:		
Tank: (TK # 7) - Existing automatic tank gauging		
<i>Piping:</i> (TK # 7) - (Installing) Veeder Root TLS350) interstitial piping sump sensors	
(f) Corrosion Protection being used:		
Tank:		
<i>Piping:</i> (TK # 7) - (Installing) Fiberglass		
(g) Spill containment devices:		
(h) Overfill prevention devices:		
(i) Manway accessible at grade:		
The owner must notify this Office when completion of tank upg Form and the licensed contractor must submit the required job prevention to the OSFM prior to the work being performed. B	schedule for underground piping upgrade, leak detection	on, spill and overfill
5) SPECIAL CONTINGENCIES:		
(6) PERSON, FIRM OR COMPANY PERFORMING WORK:		
.,	Contact Person:	
	Phone:	_
	Contractor Registration #	Exp.
Sincerely,		
Jim (Coffey	
c: Storage Tank Safety Specialist -		
Fire Department - Office Coordinator -		