



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-018165
Permit # 00602-2006LIN
Request Rec'd 04/26/2006
Amended Date 05/25/2006
Approval Date 5/1/2006 JC
Permit Expires 11/1/2006

Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Part 170. Such inspections of interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Amanath Ali Khan 2319 W. Roosevelt Road Broadview, IL 60153 Contact:	(2) FACILITY - name and address where tanks are located: Broadview Gas N Go 2319 Roosevelt Rd Broadview, Cook Co., IL Contact: Amanath Ali Khan (630) 674-6959
--	---

(3) INSPECTION OF INTERIOR LINING OF TANKS:

- (a) Number and size of tanks being inspected:* (TK # 1) - 8,000 gallons, (TK # 3) - 6,000 gallons
- (b) Type of tanks:* (TK # 3) - Existing single wall steel
- (c) Product stored in each tank:* (TK # 1) - Gasoline, (TK # 3) - Diesel Fuel
- (d) Manway accessible at grade:*

- (4) Any tank that has been out of service for a twelve-month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for the inspection of the existing interior lining only. No repairing, upgrading, or interior lining is authorized with this permit.**
- (5) The owner must notify this Office when completion of tank interior inspection has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**
- (6) SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). Amendment request received 05/25/06 to include tank #1 on the permit. This permit is essentially a permit for a "second opinion" inspection from a second contractor. The tanks have already been inspected once through permit #00384-2006LIN by a different contractor. That contractor deemed the tank "beyond repair" in his opinion. STSS should review the contingencies from the above mentioned permit for further information on this site. A Timely Compliance Opportunity letter was issued for this site on 04/21/06 allowing this facility 60 days to come into compliance. If compliance is not achieved by 06/20/06 the non-compliant underground storage tank(s) will be red-tagged.

<u>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</u>	
Chicago Tank Lining Inc 600 Hartrey _____	Contact Person: Ray Brand Phone: _____ Contractor Registration # _____ Exp. _____

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)