



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 2-043190  
Permit # 01695-2006INS  
Request Rec'd 11/01/2006  
Amended Date  
Approval Date 11/13/2006 JC  
Permit Expires 5/13/2007

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Village of Oak Park 123 Madison Street, Oak Park, IL 60302-4272  Contact: Bob Clements (708) 358-5644	<b>(2) FACILITY</b> - name and address where tanks are located:  Oak Park-Dept. of Public Works 131 South Boulevard Oak Park, Cook Co., IL  Contact:
--	--

**(3) INSTALLATION OF TANKS:**

- (a) **Number and size of tanks being installed:** (TK # 4, 5) - 8,000 gallons, (TK # 6) - 4,000 gallons
- (b) **Type of tanks:** (TK # 4, 5, 6) - (Installing) XERXES double wall fiberglass (TK # 4, 5, 6) - Tank 5 & 6 are a compartment tank.
- (c) **Type of piping:** (TK # 4, 5, 6) - (Installing) Ameron Dualoy 3000/LCX double wall fiberglass
- (d) **Product to be stored in each tank:** (TK # 4) - Diesel Fuel, (TK # 5, 6) - Gasoline
- (e) **Type of leak detection being used:**  
**Tank:** (TK # 4, 5, 6) - (Installing) OPW EECO 1500 interstitial tank sensor, (TK # 4, 5, 6) - (Installing) OPW EECO 1500 automatic tank gauge (TK # 4, 5, 6) - Contractor is installing tank gauge probes only for inventory control purposes only, - will not be used for a leak detection method.  
**Piping:** (TK # 4, 5, 6) - (Installing) FE Petro STP-MLD mechanical line leak detector, (TK # 4, 5, 6) - (Installing) OPW EECO 1500 interstitial piping sump sensors (TK # 4, 5, 6) - Interstitial sensors will be installed at all submersible sumps and all dispenser sumps.
- (f) **Corrosion Protection being used:**  
**Tank:** \_\_\_\_\_  
**Piping:** (TK # 4, 5, 6) - (Installing) Fiberglass
- (g) **Spill containment devices:** \_\_\_\_\_
- (h) **Overfill prevention devices:** \_\_\_\_\_

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

(5) **GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) **SPECIAL CONTINGENCIES:** \_\_\_\_\_

<b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b>  _____ _____ _____	Contact Person: _____ Phone: _____ Contractor Registration # _____ Exp. _____
---	---

Sincerely,

\_\_\_\_\_  
\_\_\_\_\_

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)