



**City of Chicago**  
**Department of Public Health**  
 333 South State Street, Room 200  
 Chicago, IL 60604  
 312/745-3162  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2012983
Permit #:	00070-2024UPG
Request Rec'd:	01/19/2024
Approval Date:	01/19/2024
Permit Expires:	07/19/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Khalid J Siddiqui 601 South Fifth Avenue Chicago, IL 60660 Cook County Contact: Khalid Siddiqui 773/977-0881	<b>FACILITY</b> - name and address where tanks are located: Citgo Gas Station 3645 W 79Th St Chicago, IL 60629 Cook County Contact: Rashid Mehmood 773/838-9002
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	12,000	Currently in use	Federal
5	Gasoline - Premium	6,000	Currently in use	Federal

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	New

**Summary of Work**

Replacing failed Regular spill container. Cutting back singlewall fiberglass pipe to replace the recently installed Premium STP sump due to bung adapter leaking under the sump. Reinstalling existing ball valve, flex, and submersible.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: dj.white@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

Sean Keane

**For Office Use Only**

**Tank 5 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Piping	Not Installed STP/Tanktop Sump	Removing