



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 3017240  
Permit #: 00073-2024UPG  
Request Rec'd: 01/19/2024  
Approval Date: 01/22/2024 DS  
Permit Expires: 07/23/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: LGP Realty Holdings, LP 645 Hamilton Street, Ste. 400 Allentown, PA 18101 (None) County Contact: Jeremy Holland 610/625-8061	<b>FACILITY</b> - name and address where tanks are located: IL0187 211 North Western Peoria, IL 61604 Peoria County Contact: Fahd Sanany 309/361-3477
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Single Wall STP/Tanktop Sump	New
Piping	Other Submersible Pump	New

**Summary of Work**

Remove existing STP and cut back product pipe. Install containment sump (where none currently exists), STP and flex connector. Run FRP into new containment.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/978-9937 Email: johnbu@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

Daniel Starks

**For Office Use Only**

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing