



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 312/745-3162
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	2016091
Permit #:	01458-2023UPG
Request Rec'd:	12/11/2023
Amended Date:	01/23/2024 Chi
Approval Date:	12/13/2023
Permit Expires:	06/13/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: BT-OH, LLC (Formerly Brookind Corporation) 55 Glenlake Parkway, NE Atlanta, GA 30346 Contact: Robert Harder 630/588-8720	FACILITY - name and address where tanks are located: United Parcel Service 1400 South Jefferson Street Chicago, IL 60607 Cook County Contact: Ruben Juarez 312/942-7582
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	10,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Summary of Work

Supply and install new fill and vapor recover risers
 Supply and install new double wall grade level spill bucket
 Supply and install new overfill valve

Special Contingencies

Amendment Reason:

It appears that I used the wrong tank # on the permit, so need to change this work to be for tank #2 instead of tank #1. Work was done on the correct tank, just numbered wrong on the permit

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 630/878-6354 Email: jasonre@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

Seán Keane

Sean Keane