



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY

Facility #: 2028510
Permit #: 01467-2023ABN
Request Rec'd: 12/14/2023
Amended Date: 01/25/2024 DS
Approval Date: 12/14/2023 DS
Permit Expires: 06/14/2024

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: RDK Ventures, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 Du Page County Contact: Elizabeth Sauser 708/748-3496	FACILITY - name and address where tanks are located: Circle K #6794 16707 S. LaGrange Road Orland Hills, IL 60477 Cook County Contact: Jonathan Ross 812/379-9227
---	--

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
5	4,000	E85	Inert material mixed with portland cement	

Explanation of Waiver for Abandonment

Abandoning tank. Tank is located in a field with 6 other tanks and can not be removed without damaging the other tanks. Please include abandoning the piping as well as the tank on the permit.

Special Contingencies

Amendment Reason:

Per inspector Chris he wants to include the piping on the permit.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/243-9081 Email: Steve@andersonpump.com Contractor License # IL002275 Exp. 6/10/2025

Sincerely,

Daniel Starks