



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2017221
Permit #: 00090-2024UPG
Request Rec'd: 01/25/2024
Approval Date: 01/25/2024 DS
Permit Expires: 07/25/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: St. George Petro, LLC 2 East Lake St. Northlake, IL 60164 Cook County Contact: Romany Wahaballa 224/432-7697	FACILITY - name and address where tanks are located: Northlake Marathon 2 East Lake Street Northlake, IL 60164 Cook County Contact: Romany Wahaballa 708/343-0201
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
10	Diesel Fuel	1,000	Currently in use	Federal

Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Double Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor	Reusing Existing
Piping	Ball Valves	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors

Dispensers on the Permit

Dispenser	Action
13/14	Sump / Sensors Changing

Dispenser 13/14 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Double Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

Summary of Work

Replacing T10 Diesel STP sump and submersible. Reinstalling STP sump sensor. Replacing tank interstitial sensor and UDC sensor.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: dj.white@bkequip.com
Contractor License # IL1207 Exp. 2/14/2024

Sincerely,



Daniel Starks