



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Revised

FOR OFFICE USE ONLY

Facility #: 2002419
Permit #: 00025-2024UPG
Request Rec'd: 01/08/2024
Approval Date: 01/08/2024 DS
Extension Date: 01/25/2024
Permit Expires: 07/09/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 300 West Galena, LLC 1983 Route 52 Hopewell Junction, NY 12533 (None) County Contact: Patty Garcia 845/765-8507	FACILITY - name and address where tanks are located: 300 West Galena, LLC 300 W. Galena Blvd. Aurora, IL 60506 Kane County Contact: Ibrahim Sallah 347/499-3835
---	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
8	E85	12,000	Currently in use	Federal

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump

Dispensers on the Permit

Dispenser	Action
9/10	New
11/12	New

Dispenser 9/10 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Dispenser 11/12 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Summary of Work

Replacing submersible motor on Tank 8 along with a new tank sump. Adding UDC sumps at revised fueling positions 9/10 & 11/12.

Edit for permit amendment request: Due to a hole in the STP riser on the Diesel tank, we will be replacing the existing single wall tanktop STP sump

Special Contingencies

Amendment Reason:


Scope of work changed. It was discovered after this permit was applied for that there is a hole in the severely corroded STP riser for the Diesel tank. A proposal was accepted by the customer to fix the issue and will be done in conjunction with the scope of work on the existing permit

Revision Reason:

Original work to be done, no amendment needed

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: jim.veverka@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,



Daniel Starks