

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

Permit for Emergency Repair Request on 1/18/2024

FOR OFFICE USE ONLY

Facility #: 2015723
Permit #: 00094-2024UPG
Request Rec'd: 01/25/2024
Approval Date:01/25/2024 DS
Permit Expires: 02/06/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR TEN WORKING DAYS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

RDK Ventures, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 Du Page County

Contact: Elizabeth Sauser 708/748-3496

FACILITY

- name and address where tanks are located:

Circle K #6832 16647 W. 159th Street Lockport, IL 60441 Will County

Contact: Tonya Grant 812/379-9227

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	15,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall Environ Geo Flex	Replacing - Piping - Flexible Double Wall Environ Geo Flex

Summary of Work

Replaced o-ring in Environ fitting at the STP. Had Tanknology test and opened product back up.

Special Contingencies

NOTE: A sump must be installed under a separate upgrade permit if one doesn't already exist

PERSON, FIRM OR COMPANY PERFORMING WORK:

niel J. Starke

Anderson Pump Service, Inc. 19659 South 97th Avenue

Mokena, IL 60448

Contact Person: Ron Anderson

Phone: 708/243-9081

Email: Steve@andersonpump.com

Contractor License # IL002275 Exp. 5/21/2024

Sincerely,

Daniel Starks