



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2022764
Permit #: 00099-2024UPG
Request Rec'd: 01/26/2024
Approval Date: 01/26/2024
Permit Expires: 07/26/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Jeny Corp 7550 N. Sherican Chicago, IL 60626 Cook County Contact: Jose Pinarkyil 847/832-1902	FACILITY - name and address where tanks are located: (Mobil) Leah Mol, Inc. 7550 North Sheridan Leah Mol, Inc. (Operator) Chicago, IL 60626 Cook County Contact: Jibit Joy 773/465-3450
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Diesel Fuel	10,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Submersible Pump	New
Piping	Ball Valves	New
Piping	Shear Valves	New
Piping	Flex Connector Steel	New
Piping	Single Wall STP/Tanktop Sump	New

Dispensers on the Permit

Dispenser	Action
5/6	Sump / Sensors Changing

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Summary of Work

Installing new submersible and sump on Diesel tank. Installing new dispenser sump at 5/6. Singlewall fiberglass connected to existing steel pipe.


Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: dj.white@bkequip.com
Contractor License # IL1207 Exp. 2/14/2024

Sincerely,



Sean Keane

For Office Use Only**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing