

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2021177
Permit #: 00104-2024UPG
Request Rec'd: 01/21/2024
Approval Date:01/29/2024 DS
Permit Expires: 07/30/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

True North Energy, LLC 10346 Brecksville Road Brecksville, OH 44141 (None) County

Contact: David P. Nye 440/792-4200

FACILITY

- name and address where tanks are located:

True North Station (Shell) 953

654 W. North Ave. Elmhurst, IL 60126 Du Page County

Contact: Rachael Abata 216/267-9336

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	15,000	Currently in use	Federal
7	Gasoline - Premium	8,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Summary of Work

Install OPW double wall overspills and OPW overfill drop tubes for the regular and premium tanks.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Metro Environmental Contractors, Inc. dba Metro Tank &	Contact Person: Warren Cherner			
Pump Company	Phone: 847/465-4000			
1111 West Dundee Road	Email: warren@metrotank.com			
Wheeling, IL 600903936	Contractor License # IL102 Exp. 9/20/2025			

Sincerely, Daniel J. Starks

Daniel Starks