



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 3017325  
Permit #: 00107-2024UPG  
Request Rec'd: 01/10/2024  
Approval Date: 01/29/2024 DS  
Permit Expires: 07/30/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: UTGMBH, LLC 3623 North University Peoria, IL 61604 Peoria County Contact: Terry Beachler 309/688-2488	<b>FACILITY</b> - name and address where tanks are located: Beachler Shell 3623 North University Peoria, IL 61604 Peoria County Contact: Tery Beachler 309/688-2488
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Diesel Fuel	10,000	Currently in use	Federal

**Dispensers on the Permit**

Dispenser	Action
7/8	Sump / Sensors Changing

**Dispenser 7/8 Equipment**

Equipment Type	Permit Equipment	Action
↳ Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Summary of Work**

Installing a non-discriminating sump sensor with positive shutdown under UDC 7/8.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Total Petroleum Service Company 2421 Washington Road Washington, IL 61571	Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2024

Sincerely,

Daniel Starks

**For Office Use Only**

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
↳ <i>Leak Detection - Piping</i>	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing