



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	7038604
Permit #:	00128-2024CAT
Request Rec'd:	02/01/2024
Approval Date:	02/01/2024 DS
Permit Expires:	08/01/2024

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Hathaway's One Stop, Inc. 1600 Hwy. 145 South Harrisburg, IL 62946 Saline County Contact: Julie Kuppert 618/252-3551	FACILITY - name and address where tanks are located: Hathaway's One Stop, Inc. 1600 Highway 145 South Harrisburg, IL 62946 Saline County Contact: Julie Kuppert 618/252-3551
--	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	8,000	Currently in use	Federal
3	Gasoline - Premium	4,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	STP - Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	STP - Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

**NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks**

Special Contingencies

Summary of Work

Replacing Failed Anodes with 3 New 5lb Anodes in each STP

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Midwest Tank Testing, LLC 2008 Medical Center Dr Monticello, IL 61856	Contact Person: Stephen T. Hall Phone: 217/714-4305 Email: midwesttanktestingsth@aol.com Contractor License # IL002461 Exp. 1/2/2026

Sincerely,

Daniel G. Starks

Daniel Starks