



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2021805
Permit #: 00141-2024UPG
Request Rec'd: 02/06/2024
Approval Date: 02/06/2024 DS
Permit Expires: 08/06/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: CK United, LLC 300 N. Martingale Rd. Suite 750 Schaumburg, IL 60173 (None) County Contact: Junaid Ahmed 847/884-1781	FACILITY - name and address where tanks are located: DC Gas, LLC - CK United #400179 300 S Dixie Hwy St. Anne, IL 60964 Kankakee County Contact: Almas Khan 331/684-5157
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	4,000	Currently in use	Federal
4	Gasoline - Premium	4,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Galvanized Steel Single Wall Piping	New
Piping	Shear Valves	New

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Galvanized Steel Single Wall Piping	New
Piping	Shear Valves	New

Summary of Work

Raise all shear valves to proper height.

Special Contingencies

NOTE: If piping is broken to raise shear valves, UDC's must be installed if not already existing

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

Daniel G. Starks

Daniel Starks