



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 2000499  
Permit #: 00143-2024UPG  
Request Rec'd: 02/06/2024  
Approval Date: 02/06/2024 DS  
Permit Expires: 08/06/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: CK United, LLC 300 N. Martingale Rd. Suite 750 Schaumburg, IL 60173 (None) County Contact: Junaid Ahmed 847/884-1781	<b>FACILITY</b> - name and address where tanks are located: DC Gas, LLC - CK United #4701389 807 N. Dixie Hwy. Mokenca, IL 60954 Kankakee County Contact: Almas Khan 331/684-5157
--	---

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Gasoline - Premium	8,000	Currently in use	Federal
9	Gasoline - Regular	10,000	Currently in use	Federal

**Tank 8 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Galvanized Steel Single Wall Piping	New
Piping	Shear Valves	New

**Tank 9 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Galvanized Steel Single Wall Piping	New
Piping	Shear Valves	New

**Summary of Work**

Raise all gasoline shear valves to the proper height.

**Special Contingencies**

**NOTE: If piping is broken in order to raise the shear valves then UDCs must be installed if not already existing**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

*Daniel G. Starks*

Daniel Starks