



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2001602
Permit #: 00147-2024ABN
Request Rec'd: 02/06/2024
Approval Date: 02/07/2024 DS
Permit Expires: 08/07/2024

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083 Lake County Contact: John Graham 847/223-3710	FACILITY - name and address where tanks are located: Bensenville #198 101 W. Irving Park Rd. Bensenville, IL 60106 Du Page County Contact: Julio Martinez 630/594-4903
--	---

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
5	2,000	Kerosene	Inert material mixed with portland cement	

Explanation of Waiver for Abandonment

Per the Environmental Engineer on-site:

The Kerosene tank will be abandoned in place in accordance with the 41 IAC 176 regulations since the tank is located directly adjacent to the active gasoline UST lines, and numerous electrical service lines. The removal of the Kerosene tank would lead to damage to the active gasoline lines and adjacent utilities due to the collapse of the granular fill into the tank cavity. The abandonment permit application will be submitted by the tank contractor. This report will serve as the certification required to obtain the Abandonment - in - Place permit.
The existing lines will be removed under this permit.

CONTAMINATED SITE!

IEMA Number
2024-0040

Special Contingencies

NOTE: Product lines must be removed under a separate removal permit

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 3/8/2025

Sincerely,

Daniel Starks