



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2020400
Permit #: 00163-2024UPG
Request Rec'd: 02/12/2024
Approval Date: 02/12/2024 DS
Permit Expires: 08/13/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Pulaski Real Estate, Inc. 11725 S. Pulaski Rd. Alsip, IL 60803 Cook County Contact: Stephen K. Chacko 773/671-9864	FACILITY - name and address where tanks are located: Pulaski Real Estate, Inc. 11725 S. Pulaski Rd. Alsip, IL 60658 Cook County Contact: Mansoor Khan 773/671-9864
--	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Premium	5,000	Currently in use	Federal
6	Gasoline - Regular	8,000	Currently in use	Federal
7	Gasoline - Regular	12,000	Currently in use	Federal

Dispensers on the Permit

Dispenser	Action
5/6	Sump / Sensors Changing

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Summary of Work

The flex under dispenser 5/6 is leaking and the site has no containmnet so installing UDC underneath 5/6

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2025

Sincerely,

Daniel Starks

For Office Use Only

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing