

City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2043480 Permit #: 00164-2024UPG Request Rec'd: 02/05/2024 Approval Date: 02/13/2024 Permit Expires: 08/13/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS
- Corporation, partnership, or other business entity:

89th & Chicago Property, Inc.

8903 S. Chicago
Chicago, IL 60617
Cook County

Contact: Ali Aldeiban 708/407-1866

FACILITY
- name and address where tanks are located:

89th & Chicago Property, Inc.

8903 S. South Chicago Street
Chicago, IL 60617
Cook County

Contact: Mohamed Mohsin 773/375-8169

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Diesel Fuel	6,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Leak Detection - Tank	Automatic Tank Gauging Veeder Root EMC with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Gilbarco EMC with CSLD
Piping	Shear Valves	New
Piping	Other Submersible Pump	New
\ eak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
→ Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

Summary of Work

Converting Diesel to E85 product and replacing all relevant parts to E85 compatible parts

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company 2939 175th Street Lansing, IL 60438

Contact Person: Ed Angell Phone: 708/474-3344

Email: ben.olthoff@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

Sean Keane