



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2001704
Permit #: 00165-2024CAT
Request Rec'd: 02/13/2024
Approval Date: 02/13/2024 DS
Permit Expires: 08/13/2024

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: T H Ryan Cartage Company 111 South 7th Avenue Maywood, IL 60153 Cook County Contact: Michael Ryan 708/345-0900 | FACILITY - name and address where tanks are located: T H Ryan Cartage Company 111 South 7th Avenue Maywood, IL 60153 Cook County Contact: Mike Ryan 708/345-0900 |
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|-------------|----------|------------------|------------------|
| 1 | Diesel Fuel | 10,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------------|---------------------------------------|---|
| Corrosion Protection - Tank | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection |

NACE Certified Designer

NACE Certified Designer Number

Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Replace the ground bed to include 4 MMO anodes, 300 lbs coke breeze & 6 circuit junction box. Replace the green light on the rectifier. Hydro vac truck needed for trenching and installation of anodes on the S and E sides of the tank. Dumpster on the west side would need to be removed.

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|--|
| Tanknology 880 Church Road Elgin, IL 60123 | Contact Person: Linda Przydzial Phone: 210/887-0309 Email: Dondustin@msn.com Contractor License # IL2089 Exp. 2/23/2024 |

Sincerely,

Daniel Starks