



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2010804
Permit #: 00169-2024UPG
Request Rec'd: 02/14/2024
Approval Date: 02/14/2024
Permit Expires: 08/14/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 92nd Express, LLC 8316 S. Oketo Bridgeview, IL 60455 Cook County Contact: Khalil Abdullah 708/259-4539	FACILITY - name and address where tanks are located: Citgo / Stony Fuel Mart 9155 S. Stony Island Chicago, IL 60617 Cook County Contact: Khalil Abdullah 708/247-2294
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	12,000	Currently in use	Federal
5	Gasoline - Premium	8,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Northeast - Fiberglass Double Wall Ameron Dualoy 3000/LCX	New
Piping	Shear Valves	New

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Southeast - Fiberglass Double Wall Ameron Dualoy 3000/LCX	New
Piping	Shear Valves	New

Dispensers on the Permit

Dispenser	Action
9/10	New
11/12	New

Dispenser 9/10 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 11/12 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work

Extending 2" double-wall fiberglass pipe from existing dispenser sumps to two new dispenser sumps. Adding sump sensors with positive shut-down.


Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: jim.veverka@bkequip.com
Contractor License # IL1207 Exp. 2/14/2026

Sincerely,



Sean Keane