



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3034373
Permit #: 00170-2024UPG
Request Rec'd: 02/13/2024
Approval Date: 02/14/2024 DS
Permit Expires: 08/14/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Minit Mart, LLC 165 Flanders Road Westborough, MA 015811032 (None) County Contact: Martin Hilfinger 508/270-4444	FACILITY - name and address where tanks are located: Minit Mart Peoria #613 2136 S. Airport Rd. Peoria, IL 61607 Peoria County Contact: Katie Wells 309/697-6610
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	E85	6,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket Insert
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall Transition Sump	Replacing - Leak Detect - Piping - Sump Sensor
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor

Dispensers on the Permit

Dispenser	Action
5/6	Sump / Sensors Changing

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

Summary of Work

Replacing existing single wall Spill Containment with Franklin Fueling Defender double wall Spill Containment for E-85 compatibility


Replacing existing OPV with Franklin Fueling Defender Model 708693924 Poppeted Coaxial OPV (AGB model for E-85)

Replacing existing non-discriminating sump sensors in Tank top sump, Transition sump, and UDC for dispenser 5&6 with
Veeder Root
794380-323 E-85 compatible sensors

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pemco Service Company, Inc. 1040 East Second Street Gilman, IL 60938	Contact Person: William "Butch" VonDrehle Phone: 309/828-6134 Email: pemco2@frontier.com Contractor License # IL1224 Exp. 2/26/2024

Sincerely,



Daniel Starks